



NOTE:

UPON NOTIFICATION FROM THE MONROE COUNTY HEALTH DEPARTMENT THAT A SATISFACTORY WATER SAMPLE HAS BEEN OBTAINED, REMOVE THE CORPORATION STOP AND COPPER TUBING AND INSERT A BRASS PLUG INTO THE WATER MAIN TAP AS PER SPEC. SECTION 02680, ENTITLED "WATER SYSTEM ABANDONMENTS."

DISINFECTION/BLOW-OFF/SAMPLING TAP

NOT TO SCALE

4/1/98

REVISED